



THE CORPORATION OF THE MUNICIPALITY OF ARRAN-ELDERSLIE

1925 Bruce Road 10, Box 70, Chesley, ON N0G 1L0
t 519.363.3039 f 519.363.9337 csteinhoff@arran-elderslie.ca

Request for Quotation (RFQ) 03-2025-01 ADDENDUM 3 – April 28, 2025

FOR SUPPLY AND INSTALLATION OF A CHILLER AT THE CHESLEY COMMUNITY CENTRE AND PAISLEY COMMUNITY CENTRE.

The deadline for submitting to RFQ 03-2025-01 is **Friday May 2, 2025 at 11:00am.**

Brine Testing Results:

We have received the results of the brine testing. There is trace amounts of chromate in the brine. We are requesting that if you bid on this project, that the bid is quoted as existing brine being removed and stored on site and then re-added to the new chiller.

Please price separately, supply and installation of appropriate valves for future brine filter installation at each site.

CARLY STEINHOFF
MANAGER OF FACILITIES, PARKS & RECREATION
MUNICIPALITY OF ARRAN-ELDERSLIE
1925 BRUCE ROAD 10
CHESLEY, ONTARIO
N0G 1L0
Phone: 519.363.3039
Cell: 519.270.1569
Email: csteinhoff@arran-elderslie.ca